

Michael G. Irvan
*Commissioner/
Administrative Chief*

Margaret Dimmick
Commissioner

Jeff Ramey
Commissioner



NORTH ADA COUNTY
Fire & Rescue District

Shelley Young
*Administrative
Manager*

Boise City Fire Department
Permit Supplemental Information

#27 – Liquid or gas-Fueled vehicles or Equipment in Assembly Buildings

The following list is given to you as a courtesy to help expedite the permit process. Completing these items does not guarantee approval. Full review of the plans you provide followed by a site inspection are still required for approval by the Fire Department.

Per Section 314 International Fire Code

- _ Batteries are Disconnected
- _ Fuel in tanks does not exceed one-quarter (1/4) tank or 5 gallons (whichever is least)
- _ Fuel tanks and fill openings are closed and sealed to prevent tampering.
- _ Vehicles, boats, or other motorcraft equipment are not fueled or defueled inside the building.

If you have any questions please call the office so I may assist you.

Thank You,

Joel Bradshaw

*Captain –Inspector-CFEI
Fire Prevention Division
Boise Fire Department
333 N. Mark Stall Place
Boise, Idaho 83704-0644
208-570-6578*